RSA SENSORES, CONTROLES, VALVULAS, ATUADORES, EQUIPAMENTOS, HVAC E AUTOMAÇÃO - Avenida Ragueb Chohfi, 960 - Torre 3, Sala 73 - Jardim Três Marias, São Paulo-SP, Cep: 08375-000 Telefone Sac: 55 11 2031 6658 – WHATSAPP 11 979936574 Email: <u>contato@rsa-sensors.com.br</u> Site: <u>http://www.rsa-sensors.com.br</u>

Models

RSA-TPW Pressure Transmitter




Applications & Features

For pressure measurement of compatible fluid and gas

Specifications

Sensor: glass microfused silicon strain sensor Power: 10~30VDC Output: 4~20mA (2 wires) Load: 0~500Ω@10~30VDC Range: see models Working temperature: -20~85°C Medium temperature: -40~125°C **Compensation temperature:** 0~55°C Accuracy: ±0.5%FS (BFSL) **Overload pressure: 200%FS** Burst pressure: 500%FS Medium compatibility: 17-4PH stainless steel Stability: ≤0.5%FS/Year Response time: ≤50ms Protection: IP65 Approval: CE


| Models | RSA-TPW | | | | | PressureTransmitter |
|--------------------------|---------|---|---|---|---|---------------------|
| Output | | 2 | | | | 4~20mA |
| Range | | | 2 | | | 0~6 bar |
| | | | 3 | | | 0~10 bar |
| | | | 4 | | | 0~16 bar |
| | | | 5 | | | 0~25 bar |
| | | | 6 | | | 0~40 bar |
| Process Connection | | | | 2 | | 1/4 NPT |
| | | | | 4 | | G1/4 |
| | | | | 7 | 1 | Others |
| Electrical Connection | | | | | 1 | Cable (1m) |




RSA SENSORES, CONTROLES, VALVULAS, ATUADORES, EQUIPAMENTOS, HVAC E AUTOMAÇÃO - Avenida Ragueb Chohfi, 960 - Torre 3, Sala 73 - Jardim Três Marias, São Paulo-SP, Cep: 08375-000 Telefone Sac: 55 11 2031 6658 – WHATSAPP 11 979936574 Email: <u>contato@rsa-sensors.com.br</u> Site: <u>http://www.rsa-sensors.com.br</u>

CONNECTION

Power: 24VDC (10~30VDC), red cores cable Output: 4~20mA, black cores cable





INSTRUCTION

- 1. Connect PT to the process and be sure seal with the system completely.
- 2. After 10~20 minutes power on, the output signal could be proportional to the pressure changing.
- 3. Only DC power supply is available.

ATTENTION

- 1. Finish electrical connection according to the instruction.
- 2. Do NOT crash, shock, disassemble, and break the diaphragm.
- 3. It should be installed in environment of cool, dry without corrosion.
- 4. It should be completely sealed with the process. Tightening torque should be less than 40NM.
- 5. It could be applied to the compatible medium (fluid or air) only.
- 6. Please never be over loaded.
- 7. Keep the electrical connection and cable entry out of water or moisture.
- 8. Please power off during maintenance.

Warranty

- It has limited warranty for eighteen (18) months after the production date.
- It does not extend to any unit that has been subjected to misuse or accident.
- It is, in any event, strictly limited to the replacement or repair of the product itself.



RSA SENSORES, CONTROLES, VALVULAS, ATUADORES, EQUIPAMENTOS, HVAC E AUTOMAÇÃO - Avenida Ragueb Chohfi, 960 - Torre 3, Sala 73 - Jardim Três Marias, São Paulo-SP, Cep: 08375-000 Telefone Sac: 55 11 2031 6658 – WHATSAPP 11 979936574 Email: <u>contato@rsa-sensors.com.br</u> Site: <u>http://www.rsa-sensors.com.br</u>

RSA SENSORS - ATENDIMENTO





